



Minnesota Pollution Control Agency

520 Lafayette Road North
St. Paul, MN 55155-4194

Compliance Inspection Form

Existing Subsurface Sewage Treatment Systems (SSTS)

Instructions on page 7

Parcel number: _____

System status: [] Compliant [] Noncompliant
(based on all compliance requirements)

For Local Tracking Purposes: [Empty box]

Summary Form

Property Information

Property owner name(s): _____

Property address: _____

Property owner's address (if different): _____

County: _____ Property owner phone: _____ Permitting authority: _____

Date system constructed: _____ Reason for inspection: _____

System Description

Brief system description: _____

Local permit number: _____ Number of bedrooms: _____ Design flow rate: _____

Is the system:

- In Shoreland area? [] Yes [] No
An U.S. Environmental Protection Agency (EPA) Class V Injection Well? [] Yes [] No
In Wellhead Protection Area? [] Yes [] No
System serving a Minnesota Department of Health (MDH) licensed facility? [] Yes [] No

Compliance Status (Based on state requirements - additional local requirements may also apply.)

Based on the information gathered and reported on attached forms, the compliance status of this system is (check one):

[] Certificate of Compliance - valid until (3 years from date of report): _____

[] Notice of Noncompliance - For Noncompliant systems:

The reason for noncompliance is: _____

This noncompliant system is classified as (check one below):

- [] Imminent threat to public health & safety [] Failing to protect ground water [] Not in compliance with operating permit

Certification (Completed form must be submitted to the local unit of government within 15 days.)

I hereby certify that all the necessary information has been gathered to determine the compliance status of this system. No determination of future system performance has been nor can be made due to unknown conditions during system construction, possible abuse of the system, inadequate maintenance, or future water usage.

Name: _____ Certification number: _____

Business license name and number: _____ or

Name of local unit of government: _____

Signature: _____ Date: _____

Required Attachments

Inspector Complete: This Inspection Report is _____ pages long.

- Check compliance forms attached: [] Hydraulic Performance [] Tank Integrity [] Soil Separation [] Operating Permit Form (if applicable) [] System drawing/As-built drawing [] An assessment of any local requirements that are different from what is required on this form [] Soil Boring Logs [] Abandonment form (if appropriate) [] Other information (list):

Upgrade Requirements (derived from Minn. Stat. § 115.55) An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, repaired, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.

Parcel number: _____

System status: Compliant Noncompliant
(as determined by this form)

Hydraulic Performance and Other Compliance

Compliance Issue #1 of 4

Date of observation: _____ Reason for observation: _____

This form expires upon next inspection or in three years, whichever occurs first: _____

Compliance questions/criteria: (Required)
(Check the appropriate box)

Does the system discharge sewage to the ground surface?	<input type="checkbox"/> Yes <input type="checkbox"/> No
Does the system discharge sewage to drain tile or surface waters?	<input type="checkbox"/> Yes <input type="checkbox"/> No
Does the system cause sewage backup into dwelling or establishment?	<input type="checkbox"/> Yes <input type="checkbox"/> No
Do other situations exist that have the potential to immediately and adversely impact or threaten public health or safety (electrical, unsafe covers, etc.)?	<input type="checkbox"/> Yes <input type="checkbox"/> No
Any "yes" answer indicates that the system is an imminent threat to public health and safety.	
Does the system pose a threat to ground water for any conditions deemed non-protective as determined by the inspector?	<input type="checkbox"/> Yes <input type="checkbox"/> No

"Yes" indicates that the system is failing to protect ground water. If "yes", describe the condition noted:

Verification Method*: (Optional)
(Check the appropriate box)

- Searched for surface outlet
- Performed hydraulic test
- Searched for seeping in yard
- Checked for backup in home
- Excessive ponding in soil system/D-boxes
- Homeowner testimony
- Examined for surging in tank
- "Black soil" above soil dispersal system
- System requires "emergency" pumping
- Performed dye test
- Other: _____

** No standard protocol exists. This list is not exhaustive, in sequential order, nor does it indicate which combinations are necessary to make this determination.*

Certification

This form is to be completed and attached to the Summary Form of the Minnesota Pollution Control Agency's (MPCA) **Compliance Inspection Form for Existing Subsurface Sewage Treatment Systems**. Observations, interpretations, and conclusions must be completed by an inspector. Completed form must be submitted to the local unit of government within 15 days.

Property owner name(s): _____

Property address: _____

Property owner's address (if different): _____

County: _____ Phone: _____

I hereby certify that I personally made the observations, interpretations, and conclusions reported on this form and that they are correct.

Name: _____ Certification number: _____

Business license name and number: _____ or

Name of local unit of government: _____

Signature: _____ Date: _____

Parcel number: _____ System status: _____ Compliant Noncompliant
 (as determined by this form)

Tank Integrity and Safety Compliance

Compliance Issue #2 of 4

Date of observation: _____ Reason for observation: _____

This form expires on (three years): _____

Compliance questions/criteria: (Required) (Check the appropriate box)

Does the system consist of a seepage pit*, cesspool, drywell, or leaching pit?	<input type="checkbox"/> Yes <input type="checkbox"/> No
Do any sewage tank(s) leak below their designed operating depth?	<input type="checkbox"/> Yes <input type="checkbox"/> No

If yes, identify which sewage tank leaks. _____

Any "yes" answer indicates that the system is failing to protect ground water.

* Seepage pits meeting 7080:2550 may be compliant if allowed in ordinance by local permitting authority.

Verification Method** (Optional) (Check the appropriate box)

- Probed tank bottom
- Observed low liquid level
- Examined construction records
- Examined empty (pumped) tank
- Probed outside tank for "black soil"
- Pressure/vacuum check
- Other: _____

** No standard protocol exists. This list is not exhaustive, in sequential order, nor does it indicate which combinations are necessary to make this determination.

Safety Check

1. Are any maintenance hole covers damaged, cracked, or appeared to be structurally unsound? Yes* No
2. Were all maintenance hole covers replaced in a secured manner (e.g., all screws replaced)? Yes No*
3. Was secondary access restraint present (safety pan, second cover, or safety netting) – highly recommended. Yes No
4. Was any other safety/health issue present? Yes* No

Explain: _____

***System is an imminent threat to public health and safety.**

Certification

This form is to be completed and attached to the Summary Form of the Minnesota Pollution Control Agency's (MPCA) **Compliance Inspection Form for Existing Subsurface Sewage Treatment Systems**. Observations, interpretations, and conclusions must be completed by an inspector, maintainer, or service provider. Completed form must be submitted to the local unit of government within 15 days.

Property owner name(s): _____

Property address: _____

Property owner's address (if different): _____

County: _____ Phone: _____

I hereby certify that I personally made the observations, interpretations, and conclusions reported on this form and that they are correct.

Name: _____ Certification number: _____

Business license name and number: _____ or

Name of local unit of government: _____

Signature: _____ Date: _____

Parcel number: _____

System status: Compliant Noncompliant
(as determined by this form)

Soil Separation Compliance and Other Compliance

Compliance Issue #3 of 4

Date of observation: _____ Reason for observation: _____

This information on this form does not expire.

Compliance questions/criteria: (Required)
(Check the appropriate box)

For systems built prior to April 1, 1996, and not located in Shoreland or Wellhead Protection Area or not serving a food, beverage or lodging establishment:

Does the system have at least a two-foot vertical separation distance from periodically saturated soil or bedrock?

Yes No

For non-performance systems built April 1, 1996, or later or for non-performance systems located in Shoreland or Wellhead Protection Areas or serving a food, beverage or lodging establishment:

Does the system have a three-foot vertical separation distance from periodically saturated soil or bedrock?*

Yes No

For reduced separation distance systems (i.e., "performance" systems under old 7080.0179 or Type IV or V system under new 7080.2350 or 7080.2400):

Does the system meet the designed vertical separation distance from periodically saturated soil or bedrock?*

Yes No

Any "no" answer indicates that the system is failing to protect ground water.

Verification Method:** (Optional)
(Check the appropriate box)

Conducted soil observation(s) (attach boring logs)

Two previous verifications (attach boring logs)

Other: _____

Soil observation does not expire. Previous observations by two independent parties are sufficient, unless site conditions have been altered.

* *May be reduced by up to 15 percent if allowed in local ordinance.*

** *No standard protocol exists. This list is not exhaustive, in sequential order, nor does it indicate which combinations are necessary to make this determination.*

Certification

This form is to be completed and attached to the Summary Form of the Minnesota Pollution Control Agency's (MPCA) **Compliance Inspection Form for Existing Subsurface Sewage Treatment Systems**. Observations, interpretations, and conclusions must be completed by an inspector or designer. Completed form must be submitted to the local unit of government within 15 days.

Property owner name(s): _____

Property address: _____

Property owner's address (if different): _____

County: _____ Phone: _____

I hereby certify that I personally made the observations, interpretations, and conclusions reported on this form and that they are correct.

Name: _____ Certification number: _____

Business license name and number: _____ or

Name of local unit of government: _____

Signature: _____ Date: _____

Parcel number: _____

System status: Compliant Noncompliant
(as determined by this form)

Operating Permit Compliance and Nitrogen BMP Compliance

Compliance Issue #4 of 4

Applicability:

Is the system operated under an Operating Permit? Yes No **If "yes", then complete item A, below**

Is the system required to employ a nitrogen BMP? Yes No **If "yes", then complete item B, below**

If the answer to both questions is "no", then this form does not need to be completed.

Compliance questions/criteria: (Required) (Check the appropriate box)

A. For systems with operating permits:

Has all the required monitoring and maintenance taken place and does the monitoring indicate compliance with the permit thresholds?

Yes No

B. For a system that has a required nitrogen reducing BMP and does not have an operating permit:

Is the nitrogen BMP in-place and appears to be properly operating? Yes No

Any "no" answers indicates noncompliance

Date of observation: _____ Reason for observation: _____

Operating permit number: _____

This form expires upon next inspection or in three years, whichever occurs first: _____

Certification

This form is to be completed and attached to the Summary Form of the Minnesota Pollution Control Agency's (MPCA) **Compliance Inspection Form for Existing Subsurface Sewage Treatment Systems**. Observations, interpretations and conclusions must be completed by an advanced inspector, service provider, or maintainer (maintainer for holding tanks only). Completed form must be submitted to the local unit of government within 15 days.

Property owner name(s): _____

Property address: _____

Property owner's address (if different): _____

County: _____ Phone: _____

I hereby certify that I personally made the observations, interpretations and conclusions reported on this form and that they are correct.

Name: _____ Certification number: _____

Business license name and number: _____ or

Name of local unit of government: _____

Signature: _____ Date: _____

Parcel number: _____ System status: Compliant Noncompliant
(as determined by this form)

Certificate of Abandonment

Date of observation: _____ Reason for observation: _____

Compliance questions/criteria: (Check the appropriate box)

To be in compliance, systems with no future intended use for sewage or clean water discharge must be abandoned in accordance Minn. R. 7080.2500 as determined below:

- | | |
|--------------------------------------------------------------------------------------------|----------------------------------------------------------|
| Were all the solids and liquids removed from the system? | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Were all electrical devices and devices containing mercury removed? | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Were all underground tanks removed or tanks crushed and filled with soil or rock material? | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Were all underground cavities removed or filled with soil or rock material? | <input type="checkbox"/> Yes <input type="checkbox"/> No |

****Any "no" answers indicates the system is failing to protect ground water***

Property owner name(s): _____
Property address: _____
Property owner's address (if different): _____
County: _____ Phone: _____

Certification

This form is to be completed and attached to the Summary Form of the Minnesota Pollution Control Agency's (MPCA) **Compliance Inspection Form for Existing Subsurface Sewage Treatment Systems (SSTS)**. This form does not have to be completed by a certified SSTS practitioner, but must be completed by the individual who has knowledge of how the system was abandon. Completed form must be submitted to the local unit of government within 90 days.

I hereby certify the system was abandoned in accordance with Minn. R. 7080.2500 and any local requirements.

Name: _____ Certification number: _____
Business license name and number: _____
Business address: _____
Signature: _____ Date of abandonment: _____

Instructions

Compliance Inspection Form for Existing Subsurface Sewage Treatment Systems

The Minnesota Pollution Control Agency's (MPCA) compliance inspection form must be completed for all compliance inspections of existing Subsurface Sewage Treatment Systems (SSTS) (Minn. Stat. § 115.55 subdivision 5a (i)). A compliance inspection is an inspection for the purpose of issuing a certificate of compliance or notice of noncompliance (Minn. R. ch. 7080.1100, subpart 18). Additional local forms may also be required in local ordinance; if this is the case, attach the appropriate local form(s) as well.

The inspection form is divided into six separate pages, each dealing with a separate compliance issue. The pages include: Summary Form, Hydraulic Performance and Other Compliance Form, Tank Integrity and Safety Form, Soil Separation and Other Compliance Form, Operating Permit and Nitrogen BMP Compliance Form and Certificate of Abandonment. The following table indicates which sheets need to be completed for which type of systems:

System Classification	Summary Form	Hydraulic Performance and Other Compliance Form	Tank Integrity and Safety Form	Soil Separation and Other Compliance Form	Operating Permit and Nitrogen BMP Compliance Form	Certificate of Abandonment (when applicable)
Type I and old Standard Systems	x	x	x	x		x
Type II and old "Alternative" Systems	x	x	x	x		x
Type III and old "Other" Systems	x	x	x	x		x
Type IV	x	x	x	x	x	x
Type V and old "Performance" Systems	x	x	x	x	x	x
ISTS or MSTs with nitrogen BMP	x	x	x	x	x	x
MSTs with advanced nitrogen reduction	x	x	x	x	x	x

ISTS = Individual Sewage Treatment Systems
MSTs = Mid-Sized Subsurface Sewage Treatment Systems

The purpose of multiple forms is to accommodate the different times the system may be assessed and the various individuals that may do the assessment. The goal of these forms is to document a continual state of compliance for the system. This will aid in environmental protection and the determination of compliance for such times as property transfer during the winter months.

The final determination of compliance is determined on the Summary Sheet. This compliance status is based on the supporting compliance forms. Each supporting form has an expiration date (except the Soil Separation form), and, if not expired, will be used to support the Summary Sheet. Below is an example on how the forms relate to the Summary Sheet as far as expiration dates and keeping the system in a state of continual compliance.

Example:

A Type I system is built in 2008 and the soils work was verified at the time of construction. The soil verification form is on file with the Local Unit of Government (LUG). A Maintainer pumps and inspects the tanks in June of 2011 and 2014 and finds the tanks to be in compliance and the system to be safe. The Maintainer completes the Tank Integrity and Safety Compliance Forms and gives them to the system owner. The property is to be sold in June of 2016 and a compliance inspection is required by the LUG. The inspector determines soil separation compliance by the Soil Verification Form on file with the LUG, obtains a copy of the Tank Verification form and checks the system for hydraulic performance and completes the Hydraulic Performance and Other Compliance Form and the Summary Form. The Summary Form becomes the Certificate of Compliance and is valid until June of 2019 (even though the Tank Integrity and Safety Compliance Form expires in 2017).

Most of the information required to be completed in the blank lines of the forms is self-explanatory and many helpful hints are provided on the form for the benefit of the certified individual and the system owner. However, additional helpful suggestions for successful completion of the forms are provided in this instruction sheet.

1. Summary Form

Purpose and Intent

This is the form that is completed once all the supporting information is gathered and the supporting forms are completed. This form acts as the official "Notice of Noncompliance" or "Certificate of Compliance". The supporting forms must be attached to the summary form.

Line by Line Instructions (for non self-evident queries)

System Status (top line) - The "Compliant" or "Noncompliant" Section is based on all the required forms for that system.

Property Owner Section - The "Date System Construction" query must be determined from records or owner testimony. If neither of these two sources are available, then a reasonable estimate should be made. The method used to determine the date (records, estimate, testimony, etc... could be provided near the date blank).

System Description Section - The "Local Permit Number", "Number of Bedrooms" and "EPA Class V Injection Well" queries are optional. An U.S. Environmental Protection Agency (EPA) Class V injection well is any system which serves more than one dwelling, or receives non-domestic waste, or a system which serves an Other Establishment which serves more than 20 persons per day.

The "Design Flow Rate" must be determined or estimated to determine if an advanced inspector is required to conduct the compliance inspection for that system.

Wellhead Protection Areas can be found at: <http://mdh-agua.health.state.mn.us/swa/pdwmain.cfm>.

Compliance Status Section - The compliance status required to be recorded on this form is based on state rule and state statute requirements. The compliance status is based on the supporting compliance forms. If local compliance requirements differ, that can be noted on a separate document, but the state form still needs to be completed based on state criteria.

Certification Section - The final determination of compliance must be done by an inspector (or advanced inspector for a Type IV, Type V, or system with a design flow of greater than 2,500 gallons per day).

Required Attachments Section - The number of supporting compliance forms must be noted to ensure that the supporting information is complete.

If you are filling the form out on your computer, click the "Print Preview" button at this point – this will trigger the automatic filling of system identification and Inspector information on subsequent pages.

2. Hydraulic Performance and Other Compliance Form (Compliance Issue #1)

Purpose and Intent

This form denotes compliance for surfacing of sewage or if an inspector is determining that the system is failing to protect ground water **other than** a leaking sewage tank (septic, pump, cesspool, seepage pit, etc...)

Line by Line Instructions

 (for non self-evident queries)

System Status (top line) - The "Compliant" or "Noncompliant" Section is based only on the criteria evaluated on this form, not based on criteria on other forms.

Compliance Questions/Criteria Section - The question in the lowest left-hand box which states: "Does the system pose a threat to ground water for any condition deemed to be non-protective as determined by the inspector?" is meant to allow the inspector to make a determination outside of the obvious non-protective systems (separation distance, leaky sewage tanks, etc...). These systems could include such things as a system covered by an impermeable surface.

3. Tank Integrity and Safety Compliance Form (Compliance Issue #2)

Purpose and Intent

This form denotes compliance for watertight tanks. Water tightness only refers to water tightness below the tank's designed operating depth. Non-water tightness above the designed operating depth (i.e., water leaking into the tank) may be harmful for system operation, but is likely not a direct threat to environmental protection.

Line by Line Instructions

 (for non self-evident queries)

System Status (top line) - The "Compliant" or "Noncompliant" Section is based only on the criteria evaluated on this form, not based on criteria on other forms.

4. Soil Separation Compliance and Other Compliance Form (Compliance Issue #3)

Purpose and Intent

This form denotes compliance for the required vertical separation distance to the periodically saturated soil or bedrock.

Line by Line Instructions

 (for non self-evident queries)

System Status (top line) - The "Compliant" or "Noncompliant" Section is based only on the criteria evaluated on this form, not based on criteria on other forms.

Compliance Questions/Criteria Section - The 15 percent reduction in separation distance is further explained by the following table:

System Type	Example	Required Separation Distance	Required Separation Distance with 15% Reduction
For systems built prior to April 1, 1996, and not located in Shoreland or Wellhead Protection Area or not serving a Food, Beverage or Lodging Establishment	Septic tank with trench system, built in 1980 not near a lake or stream	24 inches	24 inches (15% rule does not apply)
For non-performance systems built April 1, 1996, or later or for non-performance systems located in Shoreland or Wellhead Protection Areas or Serving a Food, Beverage or Lodging Establishment	Septic tank with a trench system, built in 1980 within a Minnesota Department of Natural Resources (DNR) Shoreland Area, Or Septic tank with trench system, built in 2001, not in a DNR Shoreland Area	36 inches	31 inches
For reduced separation distance systems (i.e., "performance" systems under old 7080.0179 or Type IV or V system under new 7080. 2350 or 7080.2400)	Septic tank with advanced treatment to a trench system	12, 24 or 36 inches	10, 21, or 31 inches

Verification Method Section - The vertical separation distance must be determined. This determination can be made by the following:

- A. A new soil boring (which does not need to be verified by another for an existing system compliance inspection).
- B. Previous borings by two independent certified individuals (one can be the original borings by the designer).
- C. For more complex or difficult site conditions, please refer to MPCA's fact sheet on determining vertical separation distance for existing systems.

The soil boring(s) must be attached to this form.

5. Operating Permit Compliance and Nitrogen BMP Compliance Form (Compliance Issue #4)

Purpose and Intent

This form denotes compliance for proper system operation as determined by compliance with the system's operating permit, or for systems which employ a best management practice for nitrogen, whether that practice is currently in-place and properly operating. These two conditions will only apply to a few systems which are required to have these measures, which began between the years 2008 and 2011.

Line by Line Instructions (for non self-evident queries)

System Status (top line) - The "Compliant" or "Noncompliant" Section is based only on the criteria evaluated on this form, not based on criteria on other forms.

Compliance Questions/Criteria Section - The assessment of the nitrogen best management practice (BMP) can be a simple visual evaluation if the BMP is still present and whether it appears to be properly functioning at the time of inspection.

6. Certificate of Abandonment Form

Purpose and Intent

This form denotes compliance with the abandonment procedure in MN Rules Chapter 7080.2500. The rule requirements are found in the Compliance Questions/Criteria Section.

This determination is more easily made during the time of abandonment. If an inspection is required on a property that may have a system in non-use, and/or a system that may have been previously abandoned, a reasonable determination must be made on the compliance of the abandonment. If the compliance status cannot be determined with a reasonable amount of effort, the inspector must list what investigation procedures were used in the attempt to determine compliance. No final compliance status can be issued if unknown.

Line by Line Instructions (for non self-evident queries)

System Status (top line) - The "Compliant" or "Noncompliant" Section is based only on the criteria determined on this form, not based on criteria on other forms.