

DEBORAH A. ERICKSON.....AUDITOR	TAMRA LASKA.....HUMAN RESOURCES
TODD O. DAHL.....SHERIFF	DARRELL PASKE.....COURT ADMINISTRATOR
DONALD F. RYAN.....ATTORNEY	SHEILA SKOGEN, CONTACT.....COMMUNITY HEALTH
LAUREEN E. BORDEN.....TREASURER	MARK LIEDL.....LAND SERVICES DIRECTOR
KATHY LUDENIA.....RECORDER	DOUGLAS R. MORRIS.....WASTE MANAGEMENT DIRECTOR
TIMOTHY J. HOULE.....ADMINISTRATOR	SUSAN M. BECK.....HUMAN SERVICES DIRECTOR
MARTYN SCHMIDT.....ASSESSOR	JIM EDER.....INFORMATION SYSTEMS DIRECTOR
LYNDON A. ROBJENT.....HIGHWAY ENGINEER	ROBERT M. NELSON.....VETERANS SERVICE OFFICER
DON SIGETY, L.S.....SURVEYOR	JOHN BOWEN.....EMERGENCY MANAGEMENT DIRECTOR

PLANNING & ZONING OFFICE
 322 LAUREL STREET, SUITE 14
 BRAINERD, MINNESOTA 56401

COUNTY COMMISSIONERS
 ROSEMARY FRANZEN, CHAIR DOUG HOUGE, VICE CHAIR
 PHIL TRUSTY PAUL M. THIEDE RACHEL REABE NYSTROM

TELEPHONE (218)824-1125
 FAX (218)824-1126 www.co.crow-wing.mn.us

Operating Permit Guidelines for Operation of an “Other System”

Issued in conjunction with Permit Number _____ Date: _____

- I. The purpose of this operating permit is to allow the installation of an “Other” system as outlined in 7080.0178, 7080.0179 and 7080.0315.

- II. As outlined in 7080.0179, several requirements must be met. Specifically:
 - a. Only sewage may be discharged into the system
 - b. Disposal of effluent must stay below grade. Surfacing effluent shall be cause for cessation of water into the drainfield.
 - c. Any equipment associated with this system must be operated under the manufacturers’ guidelines.

- III. As outlined in 7080.0310, annual reporting of the following data must be provided to this office in the time frame outlined in the Monitoring Plan. Specifically:
 - a. Reporting frequency of test results, flow data and maintenance provided to this office as spelled out in the Monitoring Plan.
 - b. Notification of this office when monitoring plan requirements are not met.
 - c. Disclosure of the overall performance of the system.

- IV. The Planning and Zoning Office has the authority to stop the flow of wastewater into the ground and require the pumping of tanks when full should the need arise.

- V. The owner bears the responsibility to ensure the guidelines outlined in both the Monitoring and Mitigation Plan and this Operating Permit are met.

Print Permittee Name: _____

Permittee Signature: _____ Date: _____